



Proposed Code Change
State Form 41186R

RETURN TO:
INDIANA DEPARTMENT OF HOMELAND SECURITY
CODE SERVICES SECTION
302 W. Washington Street Room W246
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received

Code

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY - Dashed line through material to be deleted, underline material to be added)

Use second sheet for any material requiring more space.

Code Title IMC		Edition 2006
Section number and title 502.8.1.1 (4) System requirements		Page 35
Proponent Michael J. Koppes	Title Fire Protection Engineer	
Address 401 South Grant Street, West Lafayette, IN 47907-2024		Phone 765-494-1427
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input checked="" type="checkbox"/> Delete without substitution		
Delete item 4 of section 502.8.1.1 without substitution.		
4. A manual shutoff control shall be provided outside of the room in a position adjacent to the access door to the room or in another approved location. The switch shall be a break-glass or other approved type and shall be labeled: VENTILATION SYSTEM EMERGENCY SHUTOFF.		
REASON		
There is no legitimate reason to require a manual emergency shutdown device for a hazardous exhaust system.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		